

From: Mikush David [david.mikush@xlgroup.com]

Sent: Tuesday, October 06, 2009 2:57 PM

To: structuralsafety@nist.gov

Subject: Was ground roughness "C" used in the design?

I don't know the topography in the area, but 95% of the time, the presence of open fields, parking lots, lakes, etc. warrant the use of ground roughness "C".

Dave Mikush

Senior Loss Prevention Consultant

Global Asset Protection Services, LLC

A member of the XL Capital group

13434 Sunset Lakes Cir.

Winter Garden, FL 34787

Office: 407.654.1973

Cell: 407.443.1732

Fax: 888.964.7348

Email: david.mikush@xlgroup.com

<http://www.xlgaps.com>

---

CONFIDENTIALITY: This communication, including attachments, is for the exclusive use of the addressee(s) and may contain proprietary, confidential or privileged information. If you are not the intended recipient, any use, copying, disclosure, or distribution or the taking of any action in reliance upon this information is strictly prohibited. If you are not the intended recipient, please notify the sender immediately and delete this communication and destroy all copies.